



**VMC GROUP**  
THE POWER OF TOGETHER™



## CERTIFICATE OF COMPLIANCE

### SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS



Certification No.

# VMA-47467-02C (Revision 0)

Expiration Date: 4/30/2027

**Certification Parameters:**

The nonstructural products (mechanical and/or electrical components) listed on this certificate are CERTIFIED<sup>1</sup> FOR SEISMIC APPLICATIONS in accordance with the following building code<sup>2</sup> releases.

**IBC 2015, 2012, 2009, 2006**

The following model designations, options, and accessories are included in this certification. Reference report number VMA-47467-01 as issued by The VMC Group for a complete list of certified models, included accessories/options, and certified installation methods.

**Stryten Energy; Battery Chargers, Power Supplies, Battery Eliminators  
G77D, G77DE; 6A - 400A**

The above referenced equipment is APPROVED for seismic application when properly installed<sup>3</sup>, used as intended, and contains a Seismic Certification Label referencing this Certificate of Compliance<sup>4</sup>. As limited by the tabulated values, below grade, grade, and roof-level installations, installations in essential facilities, for life safety applications, and/or of equipment containing hazardous contents are permitted and included in this certification with an Equipment Importance Factor assigned as  $I_p=1.5$ . The equipment is qualified by successful seismic shake table testing at the nationally recognized University of California Berkeley Pacific Earthquake Engineering Research Center under the witness of the ISO Accredited Product Certification Agency, the VMC Group.

Certified Seismic Design Levels			
Certified IBC	Importance $I_p \leq 1.5$ Soil Classes A-E Risk Categories I-IV Design Categories A-F	z/h $\leq 1.0$	z/h = 0.0
		$S_{DS} \leq 1.930\text{ g}$	$S_{DS} \leq 1.930\text{ g}$

Certified Seismic Installation Methods	
Directly To Non-Structural Wall/Enclosure	Directly To Structural Wall
Rigid Mounting From Unit Base To Rigid Structure	

**HEADQUARTERS**  
113 Main Street  
Bloomingdale, NJ 07403  
Phone: 973.838.1780  
Toll Free: 800.569.8423  
Fax: 973.492.8430

**CALIFORNIA**  
180 Promenade Circle  
Suite 300  
Sacramento, CA 95834  
Phone: 916.634.7771

**TEXAS**  
11930 Brittmoore Park Drive  
Houston, TX 77041  
Phone: 713.466.0003  
Fax: 713.466.1355

thevmcgroup.com





## CERTIFICATE OF COMPLIANCE

### SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

**Certified Product Table:**

Unit Type	Model	Enclosure Rating	Input Voltage (V)	Output Amperage (A)	Max Width (in.)	Max Depth (in.)	Max Height (in.)	Max Weight (lbs.)	Cabinet Case No.		
G77D, G77DE	[6-100] - 24V	NEMA 1, UL 1012	120, 208, 220, 240, 380, 480	6-100	20.5	15.9	38	290	10, 477, 977, 4875, 475, 975, 72		
	[6 - 100] - 48V						460				
	[6-78] - 130V			6-78	27	24.5	43.7	735			
	[75-400] - 24V					75-400	36	34	67.5	1050	977, 72N, 46N-1, 47N, 975, 72, 46, 47
	[50-400] - 48V					50-400				1200	
	[25-300]-130V					25-300				2200	

Group	Type	S <sub>DS</sub> (z/h=0)	S <sub>DS</sub> (z/h=1)	A <sub>Flex-H</sub>	A <sub>Rig-H</sub>	A <sub>Flex-V</sub>	A <sub>Rig-V</sub>	F <sub>p</sub> /W <sub>p</sub>
Seismic	AC156	1.93	1.93	3.09	2.32	1.29	0.52	4.34

This certification includes the product and factory supplied accessories and options. The product and included accessories and options shall be a catalogue design and factory supplied. The product shall be installed and attached to the building structure per the manufacturer supplied seismic installation instructions. This certification excludes all non-factory supplied accessories, including but not limited to enclosures, isolation/restraint devices, remote control panels, mounting brackets, and other electrical/mechanical components.



**VMA-47467-02C (Revision 0)**  
Issue Date: Tuesday, April 9, 2024  
Revision Date: Tuesday, April 9, 2024  
Expiration Date: Friday, April 30, 2027



## CERTIFICATE OF COMPLIANCE

### SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

---

#### Notes & Comments:

1. All equipment listed herein successfully passed the seismic acceptance criteria for shake testing non-structural components and systems as set forth in the ICC AC-156. The Test Response Spectrum (TRS) enveloped the Required Response Spectrum (RRS) for all units tested. The tested units were representative sample(s) of a contingent of models and all remained captive and structurally sound after the seismic shake simulation. The units also remained functionally operational after the simulation testing as functional testing was completed by the equipment manufacturer before and after the seismic simulations. Although a seismic qualified unit inherently contains some wind resisting capacity, that capacity is undetermined and is excluded from this certification. Snow/Ice loads have been neglected and thus limit the unit to be installed both indoors (covered by an independent protective structure) and out of doors (exposed to accumulating snow/ice) for ground snow loads no greater than 30 psf for all applications.
2. The following building codes are addressed under this certification:
  - IBC 2015 referencing ASCE7-10 and ICC-ES AC-156
  - IBC 2012 referencing ASCE7-10 and ICC-ES AC-156
  - IBC 2009 referencing ASCE7-05 and ICC-ES AC-156
  - IBC 2006 referencing ASCE7-05 and ICC-ES AC-156
3. Refer to the manufacturer supplied installation drawings for anchor requirements and mounting considerations for seismic applications. Required anchor locations, size, style, and load capacities (tension and shear) may be specified on the installation drawings or specified by a 3rd party. Mounting requirement details such as anchor brand, type, embedment depth, edge spacing, anchor-to-anchor spacing, concrete strength, special inspection, wall design, and attachment to non-building structures must be outlined and approved by the Engineer of Record for the project or building. Structural walls, structural floors, and housekeeping pads must also be seismically designed and approved by the project or building Structural Engineer of Record to withstand the seismic anchor loads as defined on the installation drawings. The installing contractor is responsible for ensuring the proper installation of all anchors and mounting hardware.
4. For this certificate and certification to remain valid, this certificate must correspond to the "Seismic Certification Label" found affixed to the unit by the factory. The label ensures the manufacturer built the unit in conformance to the IBC seismic design criteria set forth by the Certified Seismic Qualification Agency, the VMC Group, and meets the seismic design levels claimed by this certificate.
5. Mechanical, Electrical, and Plumbing connections to the equipment must be flexibly attached as to not transfer load through the connection. The structural integrity of any conduit, cable trays, piping, ductwork and/or flexible connections is the responsibility of others. This certification makes no statements of compliance in regards to NEMA, IP, UL, CSA, or other relevant standards after a seismic event. For compliance to other relevant standards, please contact the manufacturer.
6. This certificate applies to units manufactured at:
  - 106 Bradrock Drive, Des Plaines, IL 60018
7. This certification follows the VMC Group's ISO-17065 Scheme.

John P. Giuliano, PE  
President, VMC Group



**VMA-47467-02C (Revision 0)**  
Issue Date: Tuesday, April 9, 2024  
Revision Date: Tuesday, April 9, 2024  
Expiration Date: Friday, April 30, 2027

