



VMC GROUP
THE POWER OF TOGETHER™



CERTIFICATE OF COMPLIANCE

WIND RESISTANT DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS



Certification No.

VMA-54403-01C (Revision 0)

Expiration Date: 6/30/2028

Certification Parameters:

The nonstructural products containing non-active components, listed on this certificate are CERTIFIED¹ FOR WIND APPLICATIONS in accordance with the following building code³ releases.

IBC 2021, 2018

The following model designations, options, and accessories are included in this certification. Reference report number **VMA-54403-01** as issued by VMC Group for a complete list of certified models, included accessories/options, and certified installation methods.

Cummins; C600-900D6E & C1000D6ED Enclosure Steel Enclosure; Weather & Sound Level 2

The above referenced non-active components equipment is **APPROVED** for seismic application when properly installed², used as intended, and contains a Wind Certification Label referencing this Certificate of Compliance³. Installations in essential facilities, for life safety applications, and/or of equipment containing hazardous contents are permitted and included in this certification with an Equipment Importance Factor assigned as $I_p=1.15$.

Certified Wind Resistant Design Levels			
Certified IBC	Importance $I_p \leq 1.15$ Exposure Categories A-C Risk Categories I-IV	$V \leq 120$ mph $V \leq 53$ m/s	$V \leq 120$ mph $V \leq 53$ m/s
		$z \leq 15$ ft $z \leq 5$ m	$z \leq 500$ ft $z \leq 152$ m
		Pressure Basis ⁴	$\frac{F_h}{A_f} = q_z G C_f =$ 50.61 lbs/ft² 2.42 kPa

Certified Wind Resistant Installation Methods
Rigid Mounting From Unit Base to Rigid Structure

HEADQUARTERS
113 Main Street
Bloomington, NJ 07403
Phone: 973.838.1780
Toll Free: 800.569.8423
Fax: 973.492.8430

CALIFORNIA
180 Promenade Circle
Suite 300
Sacramento, CA 95834
Phone: 916.634.7771

TEXAS
11930 Brittmoore Park Drive
Houston, TX 77041
Phone: 713.466.0003
Fax: 713.466.1355

thevmcgroup.com





VMC GROUP
THE POWER OF TOGETHER™



CERTIFICATE OF COMPLIANCE

WIND RESISTANT DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Certified Product Table:

Godzilla Enclosure

Genset	Material	Enclosure Type	Max Dimensions [in]			Weight [lb]	Wind Velocity @ Z ≤ 15 ft Exposure Category C
			Length	Width	Height		
C600-900D6E, C1000D6ED	Carbon Steel	Sound Level 2, Weather	252	81	93	3,775	120 mph

Note: Sound Level 2 enclosure includes foam on interior panels

IBC		2021, 2018		
ASCE		7-16		
Exposure Category		B	C	D
Velocity ⁵ (mph)	Z ≤ 15 ft	146	120	109
	Z = 200 ft	100	91	87
	Z ≤ 500 ft	88	83	80



VMA- 54403-01C (Revision 0)
Issue Date: June 3, 2025
Revision Date: June 3, 2025
Expiration Date: June 30, 2028

HEADQUARTERS
113 Main Street
Bloomington, NJ 07403
Phone: 973.838.1780
Toll Free: 800.569.8423
Fax: 973.492.8430

CALIFORNIA
180 Promenade Circle
Suite 300
Sacramento, CA 95834
Phone: 916.634.7771

TEXAS
11930 Brittmoore Park Drive
Houston, TX 77041
Phone: 713.466.0003
Fax: 713.466.1355

thevmcgroup.com





VMC GROUP
THE POWER OF TOGETHER™



CERTIFICATE OF COMPLIANCE

WIND RESISTANT DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Notes and Comments:

1. The following building codes are addressed under this certification:

IBC 2018 – referencing ASCE 7-16
IBC 2021 – referencing ASCE 7-16

2. Refer to the manufacturer supplied installation drawings for anchor requirements and mounting considerations for wind applications. Required anchor locations, size, style, and load capacities (tension and shear) are specified on the installation drawings. Mounting requirement details such as anchor brand, type, embedment depth, edge spacing, anchor-to-anchor spacing, concrete strength, special inspection, wall design, and attachment to non-building structures must be outlined and approved by the Engineer of Record for the project or building. Structural walls, structural floors, and housekeeping pads must also be sufficiently designed and approved by the project or building Structural Engineer of Record to withstand the wind anchor loads as defined on the installation drawings. The installing contractor is responsible for observing the installation detailed in the wind installation drawings and the proper installation of all anchors and mounting hardware.
3. For this certificate to remain valid, it must correspond to the "Wind Certification Label" found affixed to the unit by the factory. The label ensures the manufacturer built the unit in conformance to the IBC wind design criteria set forth by the Product Certification Agency, The VMC Group, and meets the wind design levels claimed by this certificate.
4. The qualified wind design pressure stated is for the horizontal wind pressure for applications utilizing ASCE 7-16, for more detailed ranges of qualified wind design levels, see the report cited on Page 1. This wind design pressure utilizes LRFD load combinations.
5. Design velocity (highlighted in yellow) was chosen based on the corresponding ASCE 7 wind map. Other velocities were derived from the design pressure resulting from the design velocity.
6. Mechanical, Electrical, and Plumbing connections to the equipment must be flexibly attached as to not transfer load through the connection. The structural integrity of any conduit, cable trays, piping, ductwork and/or flexible connections is the responsibility of others. This certification does not guarantee the equipment will remain compliant to UL or NEMA standards after a wind action.
7. This certificate applies to units manufactured at

Cummins Power Generation, Inc., 1400 73rd Ave NE, Minneapolis, MN 55432

John P. Giuliano, PE
President, The VMC Group



VMA-54403-01C (Revision 0)
Issue Date: June 3, 2025
Revision Date: June 3, 2025
Expiration Date: June 30, 2028



HEADQUARTERS
113 Main Street
Bloomington, NJ 07403
Phone: 973.838.1780
Toll Free: 800.569.8423
Fax: 973.492.8430

CALIFORNIA
180 Promenade Circle
Suite 300
Sacramento, CA 95834
Phone: 916.634.7771

TEXAS
11930 Brittmoore Park Drive
Houston, TX 77041
Phone: 713.466.0003
Fax: 713.466.1355

thevmcgroup.com

